



**BABCOCK Laboratories, Inc.**  
*The Standard of Excellence for Over 100 Years*

Client Name: Cherokee Metro District  
 Contact: Tyler Drennan  
 Address: 6250 Palmer Park Blvd  
 Colorado Springs, CO 80915

Analytical Report: Page 4 of 17  
 Project Name: Cherokee MD - UCMR 3  
 Project Number: CO0121125

Report Date: 28-Jul-2014

Work Order Number: **B4F2398**

Received on Ice (Y/N): Yes Temp: 8 °C

Laboratory Reference Number  
**B4F2398-01**

<u>Sample Description</u>	<u>Matrix</u>	<u>Sampled Date/Time</u>	<u>Received Date/Time</u>
00025 00025	Water	06/24/14 08:40	06/25/14 9:15

Analyte(s)	Result	RDL	Units	Method	Analysis Date	Analyst	Flag
<b>Semivolatile Organic Compounds by EPA 522</b>							
1,4-Dioxane	ND	0.070	ug/L	EPA 522	07/14/14 23:42	JHR	
Surrogate: 1,4-Dioxane-d8	97.6	% 70-130		EPA 522	07/14/14 23:42	JHR	
<b>Perfluorinated Compounds by EPA 537</b>							
Perfluoro-1-octanesulfonate (PFOS)	ND	0.040	ug/L	EPA 537	06/30/14 19:48	DIS	
Perfluoro-n-octanoic Acid (PFOA)	ND	0.020	ug/L	EPA 537	06/30/14 19:48	DIS	
Perfluoro-n-heptanoic Acid (PFHpA)	ND	0.010	ug/L	EPA 537	06/30/14 19:48	DIS	
Perfluoro-n-nonanoic Acid (PFNA)	ND	0.020	ug/L	EPA 537	06/30/14 19:48	DIS	
Perfluoro-1-hexanesulfonate (PFHxS)	ND	0.030	ug/L	EPA 537	06/30/14 19:48	DIS	
Perfluoro-1-butanesulfonate (PFBS)	ND	0.090	ug/L	EPA 537	06/30/14 19:48	DIS	
Surrogate: 13C-PFHxA	112	% 70-130		EPA 537	06/30/14 19:48	DIS	
Surrogate: 13C-PFDA	94.6	% 70-130		EPA 537	06/30/14 19:48	DIS	

**ND Not Detected**

*mailing*  
 P.O. Box 432  
 Riverside, CA 92502-0432

*location*  
 6100 Quail Valley Court  
 Riverside, CA 92507-0704

P 951 653 3351  
 F 951 653 1662  
 www.babcocklabs.com

NELAP no. 02101CA  
 CA Elap no. 2698  
 EPA no. CA00102